



Government of Bermuda

Ministry of **Public Works and Environment**

Department of **Public Lands and Building**

Addendum

For

Interior and Exterior Painting, Gibbs Hill Lighthouse

Procurement No.: **0199 - RFP/08/26**

Issued: **Monday August 17, 2026**

Submission Deadline: **Friday September 11, 2026 03:00:00 PM Bermuda Local Time**

Addendum No, **1 – Issued August 25, 2026**

Addendum Type: Supplemental Information

The following addendum supersedes information contained in the solicitation document issued for this procurement to the extent referenced. This Addendum forms part of the solicitation documents and will be subject to all of the conditions set out in the contract conditions.

QUESTIONS AND REPONSES TO QUESTIONS WITH SUPPLEMENTAL INFORMATION

Question 1:	Please provide previous [current] coatings used on the Gibbs Hill Lighthouse?
Answer 1:	Exterior: Undercoat RUS-KIL Primer Red; (2) Topcoats of Sea Guard White Interior: Undercoat RUS-KIL Primer Red, (2) Topcoats of Semi Goss Marine Quality Enamel Coating. Supplier: Bermuda Paint 9 Watlington Road Devonshire 236-4662
Question 2:	Please provide engineering blasting standards and paint specifications.
Answer 2:	Please refer to Appendix D pages 23 thru 24 of the main solicitation documents titled "Interior and Exterior Painting ... "You may also refer to the General Requirements document for general conditions of work.

End of Addenda No:1