

GOVERNMENT OF BERMUDA <u>Ministry of Public Works</u> Department of Works & Engineering Concrete Floor Protection to Fort Victoria Tank

Addendum Two

DATE: 12th February 2024 PROJECT NAME & NO.: 50/820/23-FV GF Tank Floor Protection

POSTED ON www.gov.bm/procurement-notices

This Addendum forms part of the RFQ documents and will be subject to all of the conditions set out in the contract conditions. This Addendum Two contains (one) page.

Addendum Two

This addendum provides information arising from discussion at the site meeting held 12th February 2024.

- 1. The services made available to the contractor at the site consist of:
 - a. Electrical power 120v 60 hz
 - b. ³/₄" water supply delivering Reverse Osmosis water that contains a chlorine residual of up to 1ppm
- 2. The roof is not water tight and some form of covering will be required during the placement of the Basecrete.
- 3. As per the Basecrete specification Basecrete mesh is to be used for the edge fillet.
- 4. A different color basecrete shall be used for each layer to ensure continuity of coverage.

Respondents are requested to acknowledge receipt of this Addendum (One) by emailing

tjchristopher@gov.bm

Sincerely, Project Manager

END OF ADDENDUM Two