



Government of Bermuda
Ministry of Public Works
Department of Works and Engineering

Addenda
For
**Internal and External School Painting; (Port Royal Primary, Northlands Primary,
Dellwood Middle School, Somerset Primary & Paget Primary)**

Procurement No.: **2023-010Q-MPW**

Issued: **Thursday February 22, 2024**

Submission Deadline: **March 20, 2024, 03:00 P.M.**

Addenda No. **0001**

Addenda Type: Questions and Responses

The following addendum supersedes information contained in the solicitation document issued for this procurement to the extent referenced. This Addendum forms part of the solicitation documents and will be subject to all the conditions set out in the contract conditions.

1.4.2 Site Visit / Pre-Bid Meeting

Site Visit is changed to optional. Failure to be present at the site visit will not result in the disqualification of your document submission

Bidder's Questions (Q) and Government's Responses ® are shown below.

Somerset Primary School

Q1.: Should the painted mural to the external walkway be included for painting over.

A1.: Do not include for painting over this mural.

Port Royal Primary School

Q2.: Should the painted mural to the rear external walls be included for painting over.

A2.: This wall mural is to be included for painting over as per the external painting specification.

Dellwood Middle School

Q3.: Should the steel portal frame supporting structure to the gymnasium be included for painting.

A3.: The steel portal frame supporting structure to the gymnasium is to be included for painting as per the internal painting specification.

End of Addenda No:0001