
FINISHED GRADE — 3'-0" MIN. DIAMETER - FINISHED PAVEMENT 6" × 6"-10/10 WWF-/ Pre Cast Concrete Rings Supplied by W&E-MANUFACTURED C.I. VALVE BOX— Compacted screenings Full trench width WATER VALVE to support Pre Cast Concrete - HDPE WATER LINE PAVED AREAS UNPAVED AREAS (NON-TRAFFIC AREAS ONLY)

TYPICAL VALVE BOX DETAILS
N.T.S.



AIR RELIEF VALVE BOX DETAILS


I.T.S.

THE MINISTRY OF PUBLIC WORKS

P.O. Box HM525 Hamilton HMCX Bermude Phone: (441)295-5151

> DEPARTMENT OF WORKS & ENGINEERING Fax: (441)294-9087

Water & Sewage Section



PIPELINE-DETAILS

SHEET NUMBER:

SGI4

PROJECT NAME:

WATER MAIN IMPROVEMENTS ST GEORGE'S

REVISION

VALVE BOX DETAILS

N.T.S.